



INSTALLATION NOTES

Flow and return pipework as per Heat Pump manufacturers recommendation. Normally minimum size is 22mm.

A - This is a return flow when the Heat Pump is heating the domestic hot water only

B - This is a return flow when the Heat Pump is used for both, DHW and heating

JASPI UK www.jaspi.uk

Ultrastore 500 + Heat Pump
(with DHW priority control)

| DRAWN | VERSION | DATE | DRAWING REF. |
|-------|---------|------------|--------------|
| SS | | 05.01.2015 | Generic |