



* Flow and return pipework as per boiler manufacturers recommendation.
Normally minimum size is 22mm.
If an external circulation pump is required, fit it to the RETURN line.

JASPI UK www.jaspi.uk

Ultrastore 500 + Pellet Boiler
(without DHW priority control)

DRAWN	VERSION	DATE	DRAWING REF.
SS		05.01.2015	Generic