



\* Flow and return pipework as per Heat Pump manufacturers recommendation.  
Normally minimum size is 22mm.  
If an external circulation pump is required, fit it to the RETURN line.

**JASPI UK** [www.jaspi.uk](http://www.jaspi.uk)

Ultrastore 500 + Heat Pump  
(without DHW priority control)

DRAWN	VERSION	DATE	DRAWING REF.
SS		05.01.2015	Generic